

380 kV ÇİFT DEVRE 3B 1272 MCM (PHEASANT) DİREK AĞIRLIKLARI (kg.)

Direk Tipi	Direk Gövdesi	0,0,0,0 Ayaklı	İyi Zemin Bir Ayak Ağırlık Farkları (kg.)									Zayıf Zemin (MİKROKAZIK) Bir Ayak Ağırlıkları (kg.)								
			1 m	2 m	3 m	4 m	5 m	6 m	7m	8m	9m	1 m	2 m	3 m	4 m	5 m	6 m	7 m	8m	9 m
2 PA	PA±0	17,450	451	533	621	681	776	872	969			349	431	519	579	675	771			
	PA+3	19,108	451	533	621	681	776	872	969			349	431	519	579	675	771			
	PA+6	20,529	451	533	621	681	776	872	969			349	431	519	579	675	771			
	PA+9	20,748	567	645	726	839	916	987	1,120			465	543	624	737	814	886			
	PA+12	22,649	567	645	726	839	916	987	1,120			465	543	624	737	814	886			
	PA+15	24,012	567	645	726	839	916	987	1,120			465	543	624	737	814	886			
2 PB	PB±0	20,854	566	638	713	835	907	1,015				444	516	591	713	786	894			
	PB+3	22,740	566	638	713	835	907	1,015				444	516	591	713	786	894			
	PB+6	24,378	566	638	713	835	907	1,015				444	516	591	713	786	894			
	PB+9	24,782	693	772	861	976	1,074	1,187	1,398	1,499		571	650	739	854	952	1065	1277	1378	
	PB+12	26,903	693	772	861	976	1,074	1,187	1,398	1,499		571	650	739	854	952	1065	1277	1378	
	PB+15	28,655	693	772	861	976	1,074	1,187	1,398	1,499		571	650	739	854	952	1065	1277	1378	
	PB+25	31,072	0	918	1,009	1,149	1,251	0				0	0	0	0	0	0			
2 PD	PD±0	42,471	1,237	1,402	1,594	1,732	1,936	2,100	2,432			910	1,075	1,267	1,405	1,609	1,773			
	PD+3	45,637	1,237	1,402	1,594	1,732	1,936	2,100	2,432			910	1,075	1,267	1,405	1,609	1,773			
	PD+6	49,036	1,237	1,402	1,594	1,732	1,936	2,100	2,432			910	1,075	1,267	1,405	1,609	1,773			
	PD+9	49,570	1,547	1,730	1,910	2,097	2,285	2,439				1,220	1,403	1,584	1,771	1,959	2,111			2,954
	PD+12	53,224	1,547	1,730	1,910	2,097	2,285	2,439				1,220	1,403	1,584	1,771	1,959	2,111			2,954
	PD+15	56,897	1,547	1,730	1,910	2,097	2,285	2,439				1,220	1,403	1,584	1,771	1,959	2,111			2,954
2 PE	PE±0	47,334	1,604	1,840	2,034	2,264	2,531	2,748				1,213	1,449	1,643	1,873	2,140	2,357			
	PE+3	51,511	1,604	1,840	2,034	2,264	2,531	2,748				1,213	1,449	1,643	1,873	2,140	2,357			
	PE+6	55,226	1,604	1,840	2,034	2,264	2,531	2,748				1,213	1,449	1,643	1,873	2,140	2,357			
	PE+9	55,981	2,071	2,303	2,576	2,793	2,961	3,243	3,796	4,225	4,606	1,680	1,912	2,185	2,402	2,570	2,852	3,405	3,834	4,215
	PE+12	60,850	2,071	2,303	2,576	2,793	2,961	3,243	3,796	4,225	4,606	1,680	1,912	2,185	2,402	2,570	2,852	3,405	3,834	4,215
	PE+15	65,317	2,071	2,303	2,576	2,793	2,961	3,243	3,796	4,225	4,606	1,680	1,912	2,185	2,402	2,570	2,852	3,405	3,834	4,215
2 PF	PF±0	50,640	1,785	2,025	2,283	2,506	2,743	2,973	3,298			1,432	1,672	1,930	2,157	2,390	2,620			
	PF+3	55,246	1,785	2,025	2,283	2,506	2,743	2,973	3,298			1,432	1,672	1,930	2,157	2,390	2,620			
	PF+6	59,807	1,785	2,025	2,283	2,506	2,743	2,973	3,298			1,432	1,672	1,930	2,157	2,390	2,620			
	PF+9	60,607	2,346	2,574	2,787	3,125	3,281	3,589	4,061	4,584	4,831	1,993	2,220	2,434	2,771	2,927	3,236	3,708	4,231	4,478
	PF+12	66,275	2,346	2,574	2,787	3,125	3,281	3,589	4,061	4,584	4,831	1,993	2,220	2,434	2,771	2,927	3,236	3,708	4,231	4,478
	PF+15	71,109	2,346	2,574	2,787	3,125	3,281	3,589	4,061	4,584	4,831	1,993	2,220	2,434	2,771	2,927	3,236	3,708	4,231	4,478